



Board members

Joseph Donat, City Administrator | Rebecca Valk, Corporation Counsel | Dr. Brian Martinez,
Commissioner of Finance | Chris Gent, Commissioner of Public Works | Rich DuPilka, Engineer

I. Old Business

1. Bids Opened:

2. Bids – Award Recommendation:

- a) RFB-COP-06-24-01-Pulaski Pool Cover -Award Recommendation by Chris

3. Notice to Proceed Issued:

II. New Business

1. Bids currently in circulation. – Bid packages available on City Website and Bidnet Direct, or the Office of the Purchasing Agent:

- a. RFB-COP-06-24-02 Pershing Park Electrical
- b. RFB-COP-07-24-02 Purchase of 1 New Sludge Hauling Trailer

2. Bids to be Renewed-for Discussion:

3. Discussion:

- a) Taconic Elevator proposal to address Deficiencies -Chris

III. Executive Session-None

Meyco Pool Safety Pool Cover for Pulaski Pool

Bid No. RFB-COP-06-24-01

BASE BID:

Item No.	Description	Hudson Valley Pools	Blue Water Pools	USA Construction	Aquatic Dynamics
1	Pulaski Pool				
	MeycoLite Mesh Safety Cover with Installation	\$ 19,750.00	\$ 35,995.00	\$42,540.00	\$ 77,987.00
	Brand	Merlin	Loop-Loc	Loop-Loc	Meyco
	Base Bid Total:	\$ 19,750.00	\$ 35,995.00	\$ 42,540.00	\$ 77,987.00



Icon Elevator Inspection

Icon Elevator Inspection
157 Ridge Rd.
Dover, NY 12522

NAESA QEI (C-7137)
Tel (252-340-0710)
ENSURING SAFETY IN MOTION

May 22nd, 2024

City of Poughkeepsie
Municipal Building
62 Civic Center Plaza
Poughkeepsie, NY 12601

On May 22nd, 2024 at your request, Icon Elevator Inspection LLC conducted a semi-annual inspection on the elevators located at 62 Civic Center Plaza in Poughkeepsie, NY 12601. The inspection was performed in compliance with the rules and regulations of the American Society of Mechanical Engineers, ASME A17.1 Safety Code for Elevators and Escalators.

PE #1 (west), Otis LMCSS
SN# 230842, 6 Stop
Capacity 2500 LBS, 300 FPM

- ASME 17.1 (2.27.1.1)
Two way communication (phone) not working.
- ASME 17.1 (2.2.6.2)
When the pit exceeds (67 in.) in depth, an additional stop switch is required adjacent to the pit ladder and approximately (47 in.) above the pit floor.
(there is no second stop switch in the pit)
- ASME 17.1 (2.26.2.18, 2.14.1.5.1 (f))
All exit covers shall be provided with a car top emergency electrical device that will prevent operation of the elevator car if the exit cover is open more than (2 in.)
(When opened the hatch cover switch does not stop operation of the car)
- ASME 17.1 (2.2.5.2)
Pit lighting shall be externally guarded (missing pit light guards)

Best Regards,

Alex Ferrara
QEI Inspector



Icon Elevator Inspection

Icon Elevator Inspection
157 Ridge Rd.
Dover, NY 12522

NAESA QEI (C-7137)
Tel (252-340-0710)
ENSURING SAFETY IN MOTION

May 22nd, 2024

City of Poughkeepsie
Municipal Building
62 Civic Center Plaza
Poughkeepsie, NY 12601

On May 22nd, 2024 at your request, Icon Elevator Inspection LLC conducted a semi-annual inspection on the elevators located at 62 Civic Center Plaza in Poughkeepsie, NY 12601. The inspection was performed in compliance with the rules and regulations of the American Society of Mechanical Engineers, ASME A17.1 Safety Code for Elevators and Escalators.

PE #2 (east), Otis LMCSS
SN# 240842, 7 Stop
Capacity 2500 LBS, 300 FPM

- ASME 17.1 (2.27.1.1)
Two way communication (phone) not working.
- ASME 17.1 (2.2.6.2)
When the pit exceeds (67 in.) in depth, an additional stop switch is required adjacent to the pit ladder and approximately (47 in.) above the pit floor.
(there is no second stop switch in the pit)
- ASME 17.1 (2.2.5.2)
Pit lighting shall be externally guarded (missing pit light guards)

Best Regards,

Alex Ferrara
QEI Inspector



Icon Elevator Inspection

Icon Elevator Inspection
157 Ridge Rd.
Dover, NY 12522

NAESA QEI (C-7137)
Tel (252-340-0710)
ENSURING SAFETY IN MOTION

May 22nd, 2024

City of Poughkeepsie
Financial Plaza Parking Deck
41 Civic Center Plaza
Poughkeepsie, NY 12601

On May 22nd, 2024 at your request, Icon Elevator Inspection LLC conducted a semi-annual inspection on the elevators located at 41 Civic Center Plaza in Poughkeepsie, NY 12601. The inspection was performed in compliance with the rules and regulations of the American Society of Mechanical Engineers, ASME A17.1 Safety Code for Elevators and Escalators.

PE #1, Otis 211
SN# 212609, 4 Stop
Capacity 2000 LBS, 125 FPM

- ASME 17.1 (2.27.1.1)
Two way communication (phone) not working.
- ASME 17.1 (8.6.1.6.5)
Machine room requires a Class ABC fire extinguisher.

Best Regards,

Alex Ferrara
QEI Inspector



Icon Elevator Inspection

Icon Elevator Inspection
157 Ridge Rd.
Dover, NY 12522

NAESA QEI (C-7137)
Tel (252-340-0710)
ENSURING SAFETY IN MOTION

May 22nd, 2024

City of Poughkeepsie
Public Safety Building
505 Main St.
Poughkeepsie, NY 12601

On May 22nd, 2024 at your request, Icon Elevator Inspection LLC conducted a semi-annual inspection on the elevators located at 505 Main St. in Poughkeepsie, NY 12601. The inspection was performed in compliance with the rules and regulations of the American Society of Mechanical Engineers, ASME A17.1 Safety Code for Elevators and Escalators.

PE #2 (B), ThyssenKrupp Tac 20
SN# EV8959, 3 Stop
Capacity 3000 LBS, 95 FPM

- ASME 17.1 (2.27.1.1)
Two way communication (phone) not working.

Best Regards,



Alex Ferrara
QEI Inspector



Icon Elevator Inspection

Icon Elevator Inspection
157 Ridge Rd.
Dover, NY 12522

NAESA QEI (C-7137)
Tel (252-340-0710)
ENSURING SAFETY IN MOTION

May 22nd, 2024

City of Poughkeepsie
Public Safety Building
505 Main St.
Poughkeepsie, NY 12601

On May 22nd, 2024 at your request, Icon Elevator Inspection LLC conducted a semi-annual inspection on the elevators located at 505 Main St. in Poughkeepsie, NY 12601. The inspection was performed in compliance with the rules and regulations of the American Society of Mechanical Engineers, ASME A17.1 Safety Code for Elevators and Escalators.

PE #1 (A), ThyssenKrupp Tac 20
SN# EV8960, 2 Stop
Capacity 3000 LBS, 95 FPM

- ASME 17.1 (2.27.1.1)
Two way communication (phone) not working.
- ASME 17.1 (8.6.1.6.5)
Machine room requires a Class ABC fire extinguisher.

Best Regards,

Alex Ferrara
QEI Inspector

TACONIC

ELEVATOR COMPANY

Proposal

DATE: July 3, 2024

**TO: Ms. Shirley Davison
Puchasing Agent
City of Poughkeepsie**

EQUIPMENT LOCATION: 62 Civic center plaza (SN#230842, SN#240842)

Elevator Emergency phone:

Taconic Elevator Company Inc. (TEC) will provide:

- wireless gateway for emergency communication including wiring and installation \$1,700.00 (\$850 .00 per elevator)
- wireless data plan for emergency communication – \$130 per month (\$65 per month/elevator)
- Program phones with location and to call – monitoring center

Add Second Pit Stop switch:

Taconic Elevator Company Inc. (TEC) will Provide:

- Material and labor to install quantity 2 stop switches \$3,300.00 (\$1,650.00 per elevator)

Add Emergency exit switch:

Taconic Elevator Company Inc. (TEC) will provide:

- Material and labor to install quantity 2 emergency exit switches \$3,300.00 (\$1,650.00 per elevator)

Install guard on pit lights:

Taconic Elevator Company Inc. (TEC) will provide:

- Material and labor to install quantity 2 pit light guards \$850.00 (\$425.00 per elevator)

EQUIPMENT LOCATION: 41 Civic center plaza (SN#212609)

Elevator Emergency phone:

Taconic Elevator Company Inc. (TEC) will provide:

- wireless gateway for emergency communication including wiring and installation \$850 .00 per elevator
- wireless data plan for emergency communication – \$65 per month/elevator
- Program phones with location and to call – monitoring center

EQUIPMENT LOCATION: 505 Main Street (SN#EV8959, EV8960)

Elevator Emergency phone:

Taconic Elevator Company Inc. (TEC) will provide:

- wireless gateway for emergency communication including wiring and installation \$1,700.00 (\$850 .00 per elevator)
- wireless data plan for emergency communication – \$130 per month (\$65 per month/elevator)
- Program phones with location and to call – monitoring center

TACONIC

ELEVATOR COMPANY

Proposal

MISCELLANEOUS

Terms

Per existing agreement

Guarantee

TEC guarantees all material and workmanship furnished by us and, provided all payments have been made, we will make good any defects not due to ordinary wear and tear or to improper use of care which may develop within one year from the date of completion.

Clean Up

TEC shall be responsible for removal from premises of all debris and old material accumulated as a result of our work. Old material shall become our property unless otherwise specified.

TACONIC ELEVATOR COMPANY

Accepted in Duplicate

CUSTOMER

Approved by Authorized Representative

Date: _____, 20____

Signature: _____

Name: _____

Title: _____

TACONIC ELEVATOR COMPANY

Approved by Authorized Representative

Date: _____, 20____

Signature: _____

Name: _____

Title: _____